



Community Development Department • Building Inspection Division
500 Castro Street • Post Office Box 7540 • Mountain View, California 94039-7540 • 650-903-6313 • FAX 650-903-6474

UPGRADES / REVISIONS
**Sprinkler Monitoring Systems/
Fire Alarm Systems**

Submit three (3) complete sets of drawings and specifications to the City of Mountain View, Building Inspection Division, 500 Castro Street. Submittals must be made in person. Submittals received via e-mail will be returned to the sender,

A. DRAWINGS AND SPECIFICATIONS SHALL INCLUDE:

- A detailed statement describing the upgrades/revisions to be performed.
- The name, address, phone number, contractor license type and license number of the individual responsible for the upgrades/revisions.
- Manufacturer specification sheets for all equipment and materials to be used. Include the California State Fire Marshal listing sheet for each device.
- A floor plan, device layout, wiring details and sufficient details of the existing system to ascertain compatibility of the existing system and components with all new devices.
- Battery calculations and voltage drop calculations, if applicable.
- Identification of all zone changes, if applicable.

(A preliminary meeting with the Fire Protection Engineer is recommended).

B. INSPECTION AND TESTING:

Prior to the inspection, the system shall be completely pre-tested by the installer. A complete system test shall be witnessed by the Fire Protection Engineer prior to final acceptance.

Note: Please allow a minimum two (2) working days' notice when arranging an inspection.

If you should have any questions, please contact the Fire Protection Engineer at (650) 903 - 6313.